


Least Cost Electricity Mix for South Africa

Optimisation of the South African power sector until 2050

CSIR Energy Centre

Working Document, Status: 16 January 2017



Jarrad Wright
Dr Tobias Bischof-Niemz
Robbie van Heerden
Crescent Mushwana

+27 79 527 6002
+27 83 403 1108
+27 82 803 0961
+27 82 310 2142

JWright@csir.co.za
TBischofNiemz@csir.co.za
RPvHeerden@csir.co.za
CMushwana@csir.co.za

csir
our future through science

Agenda



Expertise of Commentators

Comments on IRP Assumptions

Wind Resource Data

IRP Results and Least-cost Scenario

Proposal / Next Steps

Commentators have significant expertise to give feedback on IRP & its implementation, from planning, system operation and grid perspective



Dr Tobias Bischof-Niemz

- Head of CSIR's Energy Centre
- Member of Ministerial Advisory Council on Energy (MACE)
- Member of IRP2010/IRP2013 teams at Eskom, energy planning in Europe for large utilities



Robbie van Heerden

- Senior Specialist: Energy Systems at the CSIR's Energy Centre
- Former General Manager and long-time head of System Operations at Eskom



Crescent Mushwana

- Research Group Leader: Energy Systems at the CSIR's Energy Centre
- Former Chief Engineer at Eskom strategic transmission grid planning



Jarrad Wright

- Principal Engineer: Energy Planning at the CSIR's Energy Centre
- Energy Commissioner in the National Planning Commission
- Former Africa manager of PLEXOS (software package used for the IRP)

Same software package as per the IRP was used to determine the least-cost expansion path of the South African power system to 2050

The Integrated Resource Plan (IRP) is the expansion plan for the South African power system until 2050

The IRP 2016 has a significant self-imposed limitation: The amount of wind and solar PV capacity that the model is allowed to build per year is limited, which is not technically/economically justified in the plan

The CSIR has therefore conducted a study to re-optimize the South African power mix until 2050

- First and most important deviation from IRP2016: no new-build limits on renewables (wind/solar PV)
- Additional deviation: relative costing for solar PV and wind aligned with latest relative IPP tariff results

Two scenarios from the draft IRP 2016 are compared with the re-optimisation

- “Draft IRP 2016 Base Case” – new coal, new nuclear
- “Draft IRP 2016 Carbon Budget” – significant new nuclear
- “CSIR Re-Optimised” – least-cost without constraints


An hourly capacity expansion and dispatch model (incl. unit commitment) using PLEXOS was run for all scenarios to test for technical adequacy → same software platform as IRP



CSIR uses an industry standard software package for capacity expansion planning of power system – same package as used by DoE

Commercial software used by DoE & CSIR ...

Hourly or sub-hourly chronological model of the operation of the power system after capacity expansion



Key technical limitations of power generators covered

- Maximum ramp rates (% of installed capacity/h)
- Minimum operating levels (% of installed capacity)
- Minimum up & down times (h btw start/stop)
- Start-up and shut-down profiles

... covers all key cost drivers of a power system

Costs covered in the model include

- All capacity-related costs of all power generators
 - CAPEX of new power plants (R per kW installed)
 - Fixed Operation and Maintenance (FOM) cost (R per kW installed per year)
- All energy-related costs of all power generators
 - Variable Operation and Maintenance (VOM) cost (R per kWh generated)
 - Fuel cost (R per GJ, with efficiency of power plant converts R per kWh generated)
- Efficiency (heat rate) losses due to more flexible operation
- Reserves provision (included in capacity costs)

Costs not covered in the model currently used are any grid-related costs (note: grid costs ~10-15% of power generation costs) and costs related to mimicking inertia

Agenda



Expertise of Commentators

Comments on IRP Assumptions


Wind Resource Data

IRP Results and Least-cost Scenario


Proposal / Next Steps

Actual tariffs for new solar PV and wind are 40% cheaper than new baseload coal, whereas IRP 2016 assumes similar LCOE for all three

Actual tariffs from RE IPP and Coal IPP Procurement Programme




IRP 2016 cost input assumptions




Actual tariffs for new solar PV and wind are 40% cheaper than new baseload coal, whereas IRP 2016 assumes similar LCOE for all three

Actual tariffs from RE IPP and Coal IPP Procurement Programme




IRP 2016 cost input assumptions

IRP 2016 model input assumptions in R/kWh (Jan-2015-Rand)




As per IRP 2016, inflated to April-2016-Rand, ODCs + grid connection added

Actual coal tariff of Bid Window 1 is significantly above IRP 2010 assumptions and almost exactly on the Coal PF assumption of IRP 2016




Nuclear cost assumptions increased slightly from IRP 2010 to IRP 2016



Assumptions: CPI used for normalisation to Apr-2016-Rand; LCOE calculated for IRP 2010 and 2013 with 8% discount rate (real), 60 yrs lifetime, cost and load factor assumptions as per relevant IRP document; LCOE for IRP 2016 straight from IRP document; “IRP Tariff” then calculated assuming 90% of total tariff to be LCOE EPC costs, i.e. divide the LCOE by 0.9 to derive at the “IRP Tariff”


Sources: IRP 2010; IRP 2013; IRP 2016 draft as of November 2016; <https://www.ipp-projects.co.za/Home/GetPressRelease?fileid=228bdd35-e18e-e611-9455-2c59e59ac9cd&fileName=PressRelease-Coal-based-Independent-Power-Producer-programme-announcement-10Oct2016.pdf>; CSIR analysis

Actual solar PV tariffs quickly approached IRP 2010 assumptions in first four bid windows and are now well below cost assumption funnel




Assumptions: CPI used for normalisation to Apr-2016-Rand; LCOE calculated for IRP 2010 and 2013 with 8% discount rate (real), 25 yrs lifetime, cost and load factor assumptions as per relevant IRP document; LCOE for IRP 2016 straight from IRP document; "IRP Tariff" then calculated assuming 90% of total tariff to be LCOE EPC costs, i.e. divide the LCOE by 0.9 to derive at the "IRP Tariff" Sources: IRP 2010; IRP 2013; IRP 2016 draft as of November 2016; <http://www.energy.gov.za/files/renewable-energy-status-report/Market-Overview-and-Current-Levels-of-Renewable-Energy-Deployment-NERSA.pdf>; CSIR analysis

Actual wind tariffs in bid window four were below the level that was assumed for 2030 in IRP 2010, BW 4 Expedited is significantly below



Assumptions: CPI used for normalisation to Apr-2016-Rand; LCOE calculated for IRP 2010 and 2013 with 8% discount rate (real), 20 yrs lifetime, cost and load factor assumptions as per relevant IRP document; LCOE for IRP 2016 straight from IRP document; "IRP Tariff" then calculated assuming 90% of total tariff to be LCOE EPC costs, i.e. divide the LCOE by 0.9 to derive at the "IRP Tariff" Sources: IRP 2010; IRP 2013; IRP 2016 draft as of November 2016; <http://www.energy.gov.za/files/renewable-energy-status-report/Market-Overview-and-Current-Levels-of-Renewable-Energy-Deployment-NERSA.pdf>; CSIR analysis

Actual CSP tariffs are declining from bid window 1 to 4 Expedited, and are now close to the upper boundary of IRP 2013 cost assumptions




Assumptions: CPI used for normalisation to Apr-2016-Rand; LCOE calculated for IRP 2010 and 2013 with 8% discount rate (real), 30 yrs lifetime, cost and load factor assumptions as per relevant IRP document; LCOE for IRP 2016 straight from IRP document; "IRP Tariff" then calculated assuming 90% of total tariff to be LCOE EPC costs, i.e. divide the LCOE by 0.9 to derive at the "IRP Tariff" Sources: IRP 2010; IRP 2013; IRP 2016 draft as of November 2016; <http://www.energy.gov.za/files/renewable-energy-status-report/Market-Overview-and-Current-Levels-of-Renewable-Energy-Deployment-NERSA.pdf>; CSIR analysis

IRP 2016 Solar PV cost assumptions relative to baseload coal much higher than in IRP 2010 – despite actual PV/coal ratio is much lower

Solar PV relative to baseload coal cost




- Assumptions: IRP2010
- Assumptions: IRP2016
- Actuals: REIPPPP relative to Coal IPPPP




Assumptions: CPI used for normalisation to Apr-2016-Rand; LCOE calculated for IRP 2010 and 2013 with 8% discount rate (real), 25 yrs lifetime, cost and load factor assumptions as per relevant IRP document; LCOE for IRP 2016 straight from IRP document Sources: IRP 2010; IRP 2013; IRP 2016 draft as of November 2016; <http://www.energy.gov.za/files/renewable-energy-status-report/Market-Overview-and-Current-Levels-of-Renewable-Energy-Deployment-NERSA.pdf>; CSIR analysis

IRP 2016 wind cost assumptions relative to baseload coal lower than in IRP 2010 – but actual ratios from IPP Programmes being even lower




Assumptions: CPI used for normalisation to Apr-2016-Rand; LCOE calculated for IRP 2010 and 2013 with 8% discount rate (real), 20 yrs lifetime, cost and load factor assumptions as per relevant IRP document; LCOE for IRP 2016 straight from IRP document Sources: IRP 2010; IRP 2013; IRP 2016 draft as of November 2016; <http://www.energy.gov.za/files/renewable-energy-status-report/Market-Overview-and-Current-Levels-of-Renewable-Energy-Deployment-NERSA.pdf>; CSIR analysis

IRP 2016 CSP cost assumptions relative to baseload coal higher than in IRP 2010 – actual ratios from IPP Programmes lie between IRP2010/16




Assumptions: CPI used for normalisation to Apr-2016-Rand; LCOE calculated for IRP 2010 and 2013 with 8% discount rate (real), 25 yrs lifetime, cost and load factor assumptions as per relevant IRP document; LCOE for IRP 2016 straight from IRP document Sources: IRP 2010; IRP 2013; IRP 2016 draft as of November 2016; <http://www.energy.gov.za/files/renewable-energy-status-report/Market-Overview-and-Current-Levels-of-Renewable-Energy-Deployment-NERSA.pdf>; CSIR analysis

IRP 2016 Solar PV cost assumptions relative to nuclear much higher than in IRP 2010




IRP 2016 wind cost assumptions relative to nuclear kept constant compared to IRP 2010



Assumptions: CPI used for normalisation to Apr-2016-Rand; LCOE calculated for IRP 2010 and 2013 with 8% discount rate (real), 20 yrs lifetime, cost and load factor assumptions as per relevant IRP document; LCOE for IRP 2016 straight from IRP document Sources: IRP 2010; IRP 2013; IRP 2016 draft as of November 2016; <http://www.energy.gov.za/files/renewable-energy-status-report/Market-Overview-and-Current-Levels-of-Renewable-Energy-Deployment-NERSA.pdf>; CSIR analysis

IRP 2016 CSP cost assumptions relative to nuclear significantly higher than in IRP 2010



Logic to derive “IRP Tariff” curves

Calculate the IRP LCOE path for each technology based on

- Cost development path for CAPEX in R/kW and for O&M in R/kW/yr as per IRP 2010 / IRP 2013
- Discount rate of 8%
- Lifetime of 25/20/30 years for PV/wind/CSP
- Load factors as per the profiles used in IRP 2010 / IRP 2013
- For IRP 2016, use straight the reported LCOE (i.e. without own LCOE calculation)

Adjust all resulting IRP LCOE numbers to Apr 2016 via CPI table

- <http://www.statssa.gov.za/keyindicators/CPI/CPIHistory.pdf>

Translate all Apr-2016-based IRP LCOE numbers into an “IRP Tariff”

- The IRP-assumed costs (CAPEX and O&M) reflect only the costs within the battery limit of the EPC contract. Owner's development costs (ODCs) and grid connection costs are not considered
- Assume that for an IPP the pure EPC CAPEX plus O&M stands for 90% of the total costs that lead to the tariff
- Therefore, divide “IRP LCOE” numbers by 90% to derive at the “IRP Tariff”
- This tariff is logically comparable to the tariffs that IPPs bid for in the REIPPPP

IRP 2016: Annual new-build limits for solar PV and wind are constant in absolute terms but decrease relative to the size of the power system

Draft IRP 2016
Base Case

The imposed new-build limits for solar PV and wind mean that the IRP model is not allowed in any given year to add more Solar PV and Wind capacity to the system than these limits


No such limits are applied for any other technology. No technical justification is provided for these limits. No explanation is given why these limits are constant over a 30-year period while the power system grows.

Year	System Peak Load in MW	New-build limit Solar PV in MW/yr	Relative new-build limit Solar PV	New-build limit Wind in MW/yr	Relative new-build limit Wind
2020	44 916	1 000	2.2%	1 600	3.6%
2025	51 015	1 000	2.0%	1 600	3.1%
2030	57 274	1 000	1.7%	1 600	2.8%
2035	64 169	1 000	1.6%	1 600	2.5%
2040	70 777	1 000	1.4%	1 600	2.3%
2045	78 263	1 000	1.3%	1 600	2.0%
2050	85 804	1 000	1.2%	1 600	1.9%

our future through science

Today: Both leading and follower countries install much more new solar PV capacity per year than what South Africa's limit is in 2030

Annual new solar PV capacity relative to system peak load




Today: Both leading and follower countries install much more new wind capacity per year than what South Africa's limit is in 2050


Annual new wind capacity relative to system peak load




RSA new-build limits in 2030 and 2050



Today: Solar PV penetration in leading countries 2.5 times RSA's plan for 2050 – follower countries already today almost at RSA's 2050 level



Today: Wind penetration in leading countries almost twice RSA's plan for 2050 – follower countries already today at 60% of RSA's 2050 level



Agenda



Expertise of Commentators

Comments on IRP Assumptions

Wind Resource Data

IRP Results and Least-cost Scenario

Proposal / Next Steps

The CSIR conducted a Wind and Solar PV Resource Aggregation Study

CSIR, SANEDI, Eskom and Fraunhofer IWES conducted a joint study to holistically quantify

- the wind-power potential in South Africa and
- the portfolio effects of widespread spatial wind and solar power aggregation in South Africa

Wind Atlas South Africa (WASA) data was used to simulate wind power across South Africa

Solar Radiation Data (SoDa) was used to simulate solar PV power across South Africa

Output: Simulated time-synchronous solar PV and wind power production time-series

- 5 km x 5 km spatial resolution
- Almost 50,000 pixels covering entire South Africa
- 15-minute temporal resolution
- 5 years temporal coverage (2009-2013)




A single wind farm changes its power output quickly

Simulated wind-speed profile and wind power output for 14 January 2012

14 Jan 2012 23:45 SAST

wind speed at 100m above ground





 **Fraunhofer**
IWES

 **CSIR**
our future through science



Aggregation level: 0
Number of wind pixel: 1




Aggregating 100 wind farms: 15-min gradients almost zero

Simulated wind-speed profile and wind power output for 14 January 2012

14 Jan 2012 23:45 SAST

wind speed at 100m above ground





 **Fraunhofer**
IWES



CSIR
our future through science




Aggregation level: 2
Number of wind pixel: 100



Aggregation level: 1
Number of wind pixel: 10



Five different generic wind turbine types defined for simulation of wind power output per 5x5 km pixel in South Africa (~50 000 pixels)




Turbine type no.	1	2	3	4	5
Nominal power [MW]	3	2.2	2.4	2.4	2.4
Selection criterion	$v_{80m} > 8.5 \frac{m}{s}$	$v_{80m} < 8.5 \frac{m}{s}$ and $v_{100m} > 7.5 \frac{m}{s}$	$v_{100m} < 7.5 \frac{m}{s}$	$v_{120m} < 7.5 \frac{m}{s}$	$v_{140m} < 7.5 \frac{m}{s}$
Blade diameter [m]	90	95	117	117	117
Hub height [m]	80	80	100	120	140

Space requirement 0.1km²/MW
 → max. 250 MW per pixel

On almost 70% of suitable land area in South Africa a 35% capacity factor or higher can be achieved (>50% for turbines 1-3)

Share of South African land mass less exclusion zones with capacity factors to be reached accordingly



- Installing turbine type 4 and 5 will cause higher costs but also increase capacity factors and electricity yield whilst consuming the same area

Agenda



Expertise of Commentators

Comments on IRP Assumptions

Wind Resource Data


IRP Results and Least-cost Scenario

Proposal / Next Steps

Demand grows, existing fleet phases out – gap needs to be filled

Forecasted supply and demand balance for the South African electricity system from 2016 to 2040

Electricity
in TWh/yr




All power plants considered for “existing fleet” that are either:

- 1) Existing in 2016
- 2) Under construction
- 3) Procured (preferred bidder)

csir
our future through science


Actual tariffs: new renewables projects much cheaper than first ones

First four Bid Windows' results of Department of Energy's RE IPP Procurement Programme (REIPPPP)



Key input cost assumptions for new supply technologies

Lifetime cost per energy unit¹




¹ Lifetime cost per energy unit is only presented for brevity. The model inherently includes the specific cost structures of each technology i.e. capex, Fixed O&M, variable O&M, fuel costs etc.


² Changing full-load hours for conventional new-build options drastically changes the fixed cost components per kWh (lower full-load hours → higher capital costs and fixed O&M costs per kWh);

Assumptions: Average efficiency for CCGT = 55%, OCGT = 35%; nuclear = 33%; IRP costs from Jan-2012 escalated to May-2016 with CPI; assumed EPC CAPEX inflated by 10% to convert EPC/LCOE into tariff; Sources: IRP 2013 Update; Doe IPP Office; StatsSA for CPI; Eskom financial reports for coal/diesel fuel cost; EE Publishers for Medupi/Kusile; Rosatom for nuclear capex; CSIR analysis

CSIR study cost input assumptions for solar PV: Future cost assumptions for solar PV aligned with IRP 2010




CSIR study cost input assumptions for wind: Future cost assumptions for wind aligned with results of Bid Window 4



Notes: REIPPPP = Renewable Energy Independent Power Producer Programme; BW = Bid Window; bid submissions for the different BWs: BW1 = Nov 2011; BW2 = Mar 2012; BW 3 = Aug 2013; BW 4 = Aug 2014; BW 4 (Expedited) = Nov 2015 Sources: StatsSA for CPI; IRP 2010; South African Department of Energy (DoE); DoE IPP Office; CSIR analysis


CSIR study cost input assumptions for CSP: Today's latest tariff as starting point, same cost decline as per IRP 2010



Notes: REIPPPP = Renewable Energy Independent Power Producer Programme; BW = Bid Window; bid submissions for the different BWs: BW1 = Nov 2011; BW2 = Mar 2012; BW 3 = Aug 2013; BW 4 = Aug 2014; BW 4 (Expedited) = Nov 2015 Sources: StatsSA for CPI; IRP 2010; South African Department of Energy (DoE); DoE IPP Office; CSIR analysis

CO2 emissions constrained by RSA's Peak-Plateau-Decline objective

PPD that constrains CO2 emission from electricity sector




Least-cost “CSIR Re-Optimised” case is largely based on wind and PV

As per Draft IRP 2016


Draft IRP 2016 Base Case

Total electricity produced in TWh/yr




Draft IRP 2016 Carbon Budget

Total electricity produced in TWh/yr



CSIR Re-Optimised

Total electricity produced in TWh/yr




More stringent carbon limits → No RE limits →

In the CSIR Re-Optimised case, 100 GW of wind & 60 GW of PV by 2050

As per Draft IRP 2016


Draft IRP 2016 Base Case

Total installed net capacity in GW




Draft IRP 2016 Carbon Budget

Total installed net capacity in GW



CSIR Re-Optimised

Total installed net capacity in GW




More stringent carbon limits → No RE limits →

- Solar PV
- Wind
- Gas (CCGT)
- Nuclear
- CSP
- Peaking
- Hydro+PS
- Coal

Plus 25 GW demand response from warm water provision

Draft determining the value of CSP for different capacity factors: Tipping point cost for CSP depends on annual average CF




CSP sensitivity: CSP < 1.4 R/kWh and at 20% CF is cost competitive

Comparison of energy supply for Re-Optimised base scenario and Re-Optimised with low CSP cost


CSIR Re-Optimised (base)

Total electricity
produced in TWh/yr



Re-Optimised, CSP Sensitivity

Total electricity
produced in TWh/yr



CSP annual CF @ 20%,
cost @ 1.32 R/kWh


CSP sensitivity: CSP < 1.4 R/kWh and at 20% CF is cost competitive

Comparison of energy supply for Re-Optimised base scenario and Re-Optimised with low CSP cost

**CSP annual CF @ 20%,
cost @ 1.32 R/kWh**


CSIR Re-Optimised (base)

Total installed
net capacity in GW



Re-Optimised, CSP Sensitivity

Total installed
net capacity in GW




CSP sensitivity: CSP < 0.9 R/kWh and at 60% CF is cost competitive

Comparison of energy supply for Re-Optimised base scenario and Re-Optimised with low CSP cost


CSIR Re-Optimised (base)

Total electricity
produced in TWh/yr



Re-Optimised, CSP Sensitivity

Total electricity
produced in TWh/yr




CSP annual CF @ 60%,
cost @ 0.82 R/kWh

CSP sensitivity: CSP < 0.9 R/kWh and at 60% CF is cost competitive


Comparison of energy supply for Re-Optimised base scenario and Re-Optimised with low CSP cost

CSP annual CF @ 60%,
cost @ 0.82 R/kWh

CSIR Re-Optimised (base)



Re-Optimised, CSP Sensitivity



CSP sensitivity: CSP cost below 1.4 R/kWh makes it a gas fuel saver


Sensitivity with below benchmark CSP cost

Two pre-conditions for CSP to be a cost-efficient contributor in the energy mix in 2050


- 1) CSP cost below 1.4 R/kWh @ 20% CF → today RSA: 2.0 R/kWh @ 50-60% CF, or
- 2) CSP cost below 0.9 R/kWh @ 60% CF → today RSA: 2.0 R/kWh @ 50-60% CF
- CSP fully dispatchable within a certain daily energy budget (i.e. CSP energy budget can be distributed by the System Operator as required into the 24 hours of the day, within the maximum of installed capacity)

If these two conditions are met, then CSP can play the role of a gas fuel saver and displaces wind in 2050

Electricity supplied
in 2050 in TWh/yr



Installed net capacity
in 2050 in GW



Solar PV
CSP
Wind
Other
Peaking
Gas (CCGT)
Hydro+PS
Nuclear
Coal


csir
our future through science

Draft CSP Sensitivity for CSP 20% Capacity Factor: Typical hourly dispatch profile of different generators in 2050

Demand and Supply in GW

Example Week under CSIR Re-Optimised 2050

CSP with 20% CF
@ 1.32 R/kWh




Draft CSP Sensitivity for CSP 60% Capacity Factor: Typical hourly dispatch profile of different generators in 2050

Demand and Supply in GW

Example Week under CSIR Re-Optimised 2050

CSP with 60% CF
@ 0.82 R/kWh



Monday

Tuesday

Wednesday

Thursday

Friday

Saturday

Sunday

Solar PV
Wind
CSP

DR
OCGT
Hydro, PS

CCGT
Other (RE)
Other (incl. cogeneration)

Coal
Nuclear


Demand
Demand +PS (charging)
Demand + PS (charging) + DR

Draft CSP Sensitivity for CSP 90% Capacity Factor: Typical hourly dispatch profile of different generators in 2050

Demand and Supply in GW

Example Week under CSIR Re-Optimised 2050

CSP with 90% CF
@ 0.69 R/kWh



CSIR Re-Optimised case without renewables limits is R90 billion/yr cheaper than both IRP 2016 Base Case & IRP 2016 Carbon Budget case

Draft IRP 2016 Base Case



27%



R580 billion/yr

CO_2 200 Mt/yr

40 bn l/yr

Draft IRP 2016 Carbon Budget



33%



R580 billion/yr

CO_2 100 Mt/yr

16 bn l/yr

CSIR Re-Optimised



80%



R490 billion/yr

CO_2 70 Mt/yr

11 bn l/yr

csir
our future through science

Preliminary
Year 2050

Agenda



Expertise of Commentators

Comments on IRP Assumptions

Wind Resource Data

IRP Results and Least-cost Scenario

Proposal / Next Steps

Recommendation:

The IRP Base Case should be least-cost, free of any artificial constraints

Solar PV, wind and flexibility is the cheapest new-build mix for the South African power system and it is the cost-optimal expansion to aim for a >70% renewable energy share by 2050

This “CSIR Re-Optimised” mix is R90 billion per year cheaper by 2050 than current Draft IRP Base Case

Also, CSIR Re-Optimised mix reduces CO2 emissions by 65% (-130 Mt/yr) compared to Draft IRP Base Case

Avoiding CO2 emissions and least-cost is not a trade-off anymore – South Africa can de-carbonise its electricity sector at negative carbon-avoidance cost

Recommendation: The IRP Base Case should be least-cost, free of any artificial constraints

- New-build limits for renewables should be lifted, relative costs of wind/PV updated, and the unconstrained re-run should form the Base Case of the IRP 2016
- Any cost increase due to deviations from the least-cost Base Case should be reported on



Re a leboga
Ha Khensa

Enkosi
Siyathokoza

Thank you

Re a leboga

Ro livhuha

Siyabonga


Dankie





BACKUP

REBID 1-4 amounts to only 6.8 GW of Wind and PV, the grid has more than enough capacity (≈ 85 GW) by year 2022




Additional studies (stability etc.) to quantity how much of the 85 GW can be comprised of wind and PV (with flexible generators) are warranted for managing the rollout plan

GCCA – Generation Connection Capacity Assessment

Sources:

- Transmission development plan 2016-2025: http://www.eskom.co.za/Whatweredoing/TransmissionDevelopmentPlan/Pages/Transmission_Development_Plans.aspx
- GCCA 2022: <http://www.eskom.co.za/Whatweredoing/GCCAReport/Pages/Default.aspx>
- CSIR analyses

Lack of location-based incentives for IPPs leads to interest in substations that are already constrained (e.g. RE Bid 4 Expedited)



Low risk:
Capacity available

Medium risk:
Minimal grid infrastructure required

High risk:
Extensive grid infrastructure required at Tx level

For Bid Window 4 Expedited, only 1170 MW was allocated for wind (650 MW) and PV (520 MW); more could have been allocated

Sources:

- Eskom Transmission Grid Planning - Expedited Bid Window Programme Access Risk Assessment
- CSIR analysis

Grid assessment/information to accompany the formal submission – all to be based publicly available information and data sets

- Grid capacity available at all busbars (66/88/132/275/400 kV) in transmission substations after RE Bid Windows 1-4
- Wind and solar PV correlation/aggregation impact on grid capacity assessment
- Location of wind and PV plants for the least-cost optimised electricity generation mix by 2050
- The estimated grid cost for the integration of new generation capacity for each scenario studies
- High-level assessment of the variable RE penetration levels for South Africa that will necessitate detailed stability and other studies associated with a South African system with low inertia

Actual experience from power systems globally indicate that > 50% instantaneous penetration of variable RE is possible before stability issues are a cause for concern