

UNIVERSITEIT • STELLENBOSCH • UNIVERSITY jou kennisvennoot • your knowledge partner

# Economic Impacts of Mechanisation and In-House Renewable Energy Generation and Integration in African CPO Mills

R.K. Padi

Promoters:

Dr. A.F.A Chimphango

Prof. J.F. Görgens







- Background
- Problem Statement
- > Objectives
- Process Modelling Approach
- Results
- Conclusion





#### **Oil Palm value chain**



3





- Dominating traditional Processing (>80 %)
- Inherent setbacks of traditional technologies
  - Lower production capacities
  - Labour Intensive
  - Poor product quality



Overall low productivity- Mechanisation addresses aforementioned challenges

Objecti

Modelling Approach

Results



### Reasons for less adoption of mechanised units?

- Perceived risk on profit margins
- Lack of diverse energy
- Social acceptance







Develop process models for various levels of mechanization in the CPO process

Determine the potential contribution of the process biomass residue to its energy demands.

To establish the economic impact of mechanization and in-house energy integration in the CPO process



## Modelling Approach



# Simplified CPO process flow diagram





# Process configurations investigated

### Traditional

## Semi-Mechanised

### Mechanised



Background

Problem Statement

Objectives

R

Process

Modelling

Approach

Conclusions



Traditional and semi-mechanised

Thermal energies by combusting solid residues in Improved cook stoves

Mechanised (steam, hot water & electricity)

- Cogeneration of heat and power (CHP) from solid residues (MF, PKS, EFB)
- Cogeneration of heat and power from Biogas (POME)





- EFB has high moisture (65%) & less combustible
- Two scenarios investigated:



I: No EFB addition

2: Shredding & drying EFB + conventional fuel





- Steam turbine power-to-heat ratio between 0.1 0.3 (US EPA, 2007)
- Process model developed in Aspen Plus® simulation software
- Economic assessment based on Ghana's year 2014 conditions (Interest rate -24%; Inflation rate -15%)





# Cogeneration (CHP) from solid residues

#### Results

Technical Performance						
Annual rate of generation	Scenario 1	Scenario 2				
MF (tons/yr)	13141.44	13141.44				
PKS (tons/yr)	6836.47	6836.47				
EFB (tons/yr)	-	45576.46				
CPO Process steam (tons/yr)	40884.48(100)*	40884.48(100)*				
CPO Process hot water (tons/yr)	31074.86(100)*	31074.86(100)*				
EFB drying steam (tons/yr)	-	161840.62				
CPO process electricity (MW/yr)	1654.85(100)*	1654.85(100)*				
Export electricity (MW/yr)	4705.64	17040.79				

 $^{st}$  Values in parenthesis represents percentage of energy demand of the 13 ton FFB/hr CPO mill attained

#### **Economic Performance**

Parameters		Electricity s.p. of \$0.207/kWh		Electricity s.p. of \$0.348/kWh	
		Scenario 1	Scenario 2	Scenario 1	Scenario 2
NPV (million \$)		-27.96	-55, 91	-22.03	-38.85
IRR (%)		0.10	1.42	9.94	12.93
Payback period (yrs)		24.8	23.2	15.5	13
Background P St	roblem atement	Scope of Study	Objectives	Process Modelling Approach	Conclusions

R

Conclusions

- Both Scenarios investigated **CAN MEET** in-house energy demand with excess electricity for export.
- Scenario I and 2 did NOT achieve expected IRR of 40%. Scenario 2 (EFB addition) improved the economics from IRR of 9.94% to 12.93%
- Realistic electric price at \$1.132/kWh and \$0.842/kWh for Scenario I and Scenario 2 respectively (for IRR of 40%).
- Scenarios I and 2 attained NPVs of \$2.145 million and \$1.774 million at grant contributions of 80 and 65% respectively at prevailing power price of \$0.348/kWh. Thus both are viable under grant funding.

Background

Obje



Modelling Approach Conclusions

# Cogeneration (CHP) from **Biogas (POME)**

- Palm oil mill Effluent (POME) biogas yield of 2.65 4.96 m<sup>3</sup>m<sup>-3</sup> day<sup>-1</sup> (Yeoh, 2004).
- Scenarios investigated: Steam-turbine and Gas-engine routes
- CHP process modelled in Aspen Plus® simulation software
- Economic assessment based on Ghana's year 2014 economic conditions (Interest rate -24%; Inflation rate -15%)





- Steam turbine process- similar to solid residue CHP
- Gas-engine process



Background

Scope of

Process

# S Cogeneration (CHP) from **Biogas (POME)**

### Results

Technical Performance					
Annual rate of generation	Gas-engine route	Steam turbine route			
Biogas (tons/yr)	2073.326	2073.326			
CPO Process steam (tons/yr)	2308.198 (5.65)*	11742.602 (28.72) <sup>*</sup>			
CPO Process hot water (tons/yr)	29880 (96.16)*	-			
CPO process electricity (MW/yr)	1654.85 (100) <sup>*</sup>	368.865 (22.29)*			
Export electricity (MW/yr)	1117	-			

\* Values in parenthesis represents percentage of actual energy demand by the 13 ton FFB/hr CPO mill attained

Economic Performance						
Deventer		Electricity s.p. of \$0.207/kWh		Electricity s.p. of \$0.348/kWh		
Parameters	Gas-engine		Steam turbine	Gas-engine	Steam turbine	
NPV (million \$)		-6.38	-14.46	-4.71	-14.22	
IRR (%)		7.80	-0.77	14.89	0.18	
Payback period (yrs)		11.3	14.3	9	13.7	

Background

Problem tatement

Objectives

ctives 💦 N

Results



# R

18

#### Conclusions

- Gas-engine and steam-turbine **NOT** meet all in-house energy demand. Gas-engine route attained all process electricity demand with excess for export.
- Both routes investigated did NOT attain expected IRR of 40%. Gas-engine route more promising with IRR of 14.9% at \$0.348/kWh.
- Realistic electricity price at \$0.753/kWh and \$9.403/kWh for gas-engine route and steam-turbine route respectively (for IRR of 40%)
- At power price of \$0.348/kWh, Gas engine attained NPV of \$158000 at 40% grant; steam turbine NPV of \$1.834 million at 90% grant. At \$0.207/kWh, gas-engine NPV of \$234000 at 60% grant; steam turbine NPV of \$576000 at 90% grant. Thus both viable under grant funding.



- Mechanised I/C adopted CHP solid residue (+EFB) (100% in-house energy attained & competitive power price of \$0.842/kWh)
- Substituting external energy firewood (traditional), and national grid power (mechanized) with available CPO process biomass residues is feasible.
- The highest and least energy intensive processes: semi-mechanized B/C (37.058 MJ/kg CPO) and mechanized B/C or I/C (6.007 MJ/kg CPO) respectively.





## **Economic Results of CPO Process**



- Variation in TCI ranging \$4464 \$17.746 million due to difference in capacities
- SCI ranging \$0.013/kg \$0.055/kg with semi-mechanised level having least range of \$0.013 0.019/kg while mechanised level attained highest range of \$0.053 0.055/kg
- At B/C scenarios, traditional level's SPC was higher than the semi- and mechanised level's by 15.25% and 63.66% and by 31.90% and 42.73% at I/C scenarios respectively. Thus, suggesting a high benefit of economies of scale on the production cost.





## **Economic Results of CPO Process**



Semi-Mechanised CPO CCF



#### NPV of -\$109,334 & \$301,643







22

- For (B/C), only the mechanized process is economically viable with an NPV of \$18.5 million and IRR of 47.23%.
- For I/C: semi-mechanized and mechanized processes are the economically viable options with IRR of 143% and 40.57% respectively.
- Poor performances of traditional- B/C & -I/C and the semi-mechanized B/C mainly due to their unduly high SCI ranging \$0.019 – 0.053/kg and SPC between \$0.431 – 1.187/kg as they still remained unviable under 100% grant funding
- Thus mechanization is economically beneficial in CPO processing
- In-house energy from process residue is viable and most promising at semi-mechanized and mechanized levels.



UNIVERSITEIT • STELLENBOSCH • UNIVERSITY jou kennisvennoot • your knowledge partner



Department for

International

Development

Engineering and Physical Sciences Research Council



Department of Energy & Climate Change



CENTRE FOR RENEWABLE & GUSTAINABLE ENERGY STUDIES

# **Thank You!**

Fakulteit Ingenieurswese • Faculty of Engineering